

Test report


Test items	Lifting test
Test object	LWW-WZB-W55-L12 bracket
Purpose of detection	The lifting capacity of the support
Test time	2024-12-16

Final test conclusion: LWW-WZB-W55-L12 bracket refer to GB 7000.1-2015 lamps and lanterns Part 1: General requirements and 4.14.1 content After the experiment, no obvious deformation of the bracket was found, and the lifting weight test passed. The results of this experiment are only responsible for the sample results!


Experimental methods and steps:
Refer to GB 7000.1-2015 lamps Part 1: General requirements and test 4.14.1 content of the experiment

- 1. Weigh out the weight of the lamp (3.14kg) and record it.
- 2. Mount the light fixture on the shelf and attach 12.57kg of material to the light fixture, a total of 4 times the weight of the lamp body.

Test data:



Light weight (3.14kg)



The weight of the lifting material is 12.57kg



Support test



After the stent test

Test results: There was no obvious deformation after the support was subjected to four times the weight of the lamp body for 1H.